

Permit/Checklist for Heta Arbeten®

Work site:.....

Call-out address:.....

Work method: Welding Angle grinding Cutting Soldering/ brazing Hot air Bitumen boiler
 Other.....

The permit is valid from (date) (time)..... until (date)..... (time).....
 (The permit must be issued for as short time as possible, normally not longer than one day/one shift)

Does the work represent a fire hazard? (MME method) Yes No

Yes No

- 0 A permit issuer has been appointed.
- 1 The person who is to carry out the work is authorised to perform hot work.
- 2 a Fire-watch during the work is arranged through an authorised fire-watcher.
 Name(s) of fire-watcher(s):
 The permit issuer considers that a fire-watcher is clearly not needed during this work.
- 2 b Post-hot work fire-watch (always at least one hour) has been arranged through an authorised fire-watcher.
 Different, longer time:..... Fire-watcher for post-hot work fire-watch:
- 3 A permit for working in an area that contains or has contained flammable goods must be obtained from the person appointed as superintendent for the handling of such goods.
- 4 The work site is cleared and if necessary wetted.
- 5 Combustible material at and close to the work site is removed, protected by covering and/or screened off.
- 6 a There are concealed heat-conducting structures and concealed combustible structural elements.
- 6 b These are protected and accessible for immediate fire-fighting.
- 7 a There are gaps, holes, penetrations and other openings at and close to the work site.
- 7 b These are sealed or checked and protected.
- 8 Approved, functioning and sufficient fire-fighting appliances of the correct type are available for immediate fire-fighting.
- 9 a Welding equipment will be used in the work.
- 9 b Welding equipment is free from defects. The acetylene cylinder is fitted with a flashback arrestor. Welding torches are fitted with check valves for the fuel gas and oxygen. Protective gloves and a stop key are available.
- 10 The emergency services/fire brigade can be called out immediately.
- 11a In waterproofing or other drying/heating, the gas flame is enclosed.
- 11b The permit issuer allows an open flame to be used to melt snow and ice.
- 12 In the drying of substrate and application of waterproofing, the material is heated to max. 300 °C.
- 13 For the melting of bitumen, the equipment is handled in accordance with with the Swedish Fire Protection Association's document "Melting of bitumen for work on roofs and balconies".

The following sections/addresses in the automatic fire alarm are disconnected during the work (use form SBF 175)

Signature of permit issuer All the safety rules have been fulfilled and work can begin.

| Signature | Name in block capitals | Telephone number | | | |
|---|------------------------|------------------|------------------------------------|--------------------------|--------------------------|
| Signature of hot works operative (HWO) and fire-watcher (FW) | | | Certificate check performed | HWO | FW |
| | | | (by permit issuer) | | |
| | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Signature | Name in block capitals | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Signature | Name in block capitals | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Signature | Name in block capitals | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Signature of permit issuer Work completed, post-hot work fire-watch period completed and fire safety at the work site checked.

.....
 Signature Name in block capitals

